



NEMO|etc.

Certificate of Authorization #32455
353 Christian Street, Unit #13
Oxford, CT 06478
(203) 262-9245

ENGINEER

EVALUATE

TEST

CONSULT

CERTIFY

EVALUATION REPORT

Owens Corning Roofing and Asphalt, LLC

One Owens Corning Parkway
Toledo, OH 43659
(740) 321-6345

Evaluation Report I40510.02.12-R7

FL15216-R6

Date of Issuance: 02/17/2012

Revision 7: 02/11/2020

SCOPE:

This Evaluation Report is issued under **Rule 61G20-3** and the applicable rules and regulations governing the use of construction materials in the State of Florida. The documentation submitted has been reviewed by Robert Nieminen, P.E. for use of the product under the Florida Building Code and Florida Building Code, Residential Volume. The products described herein have been evaluated for compliance with the **6th Edition (2017) Florida Building Code** sections noted herein.

DESCRIPTION: RhinoRoof U20, ABC Pro Guard 20 and SRS TopShield TS20 Roof Underlayments

LABELING: Labeling shall be in accordance with the requirements of the Accredited Quality Assurance Agency noted herein.

CONTINUED COMPLIANCE: This Evaluation Report is valid until such time as the named product(s) changes, the referenced Quality Assurance documentation changes, or provisions of the Code that relate to the product change. Acceptance of this Evaluation Report by the named client constitutes agreement to notify Robert Nieminen, P.E. of any changes to the product(s), the Quality Assurance or the production facility location(s). NEMO|etc. requires a complete review of this Evaluation Report relative to updated Code requirements with each Code Cycle.

ADVERTISEMENT: The Evaluation Report number preceded by the words "NEMO|etc. Evaluated" may be displayed in advertising literature. If any portion of the Evaluation Report is displayed, then it shall be done in its entirety.

INSPECTION: Upon request, a copy of this entire Evaluation Report shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This Evaluation Report consists of pages 1 through 4.

Prepared by:

Robert J.M. Nieminen, P.E.

Florida Registration No. 59166, Florida DCA ANE1983



The facsimile seal appearing was authorized by Robert Nieminen, P.E. on 02/11/2020. This does not serve as an electronically signed document.

CERTIFICATION OF INDEPENDENCE:

1. NEMO ETC, LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products it evaluates.
2. NEMO ETC, LLC is not owned, operated or controlled by any company manufacturing or distributing products it evaluates.
3. Robert Nieminen, P.E. does not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the evaluation reports are being issued.
4. Robert Nieminen, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.
5. This is a building code evaluation. Neither NEMO|etc. nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this Evaluation Report, or previous versions thereof, is/was used for permitting or design guidance unless retained specifically for that purpose.

©2019 NEMO ETC, LLC

ROOFING COMPONENT EVALUATION:
1. SCOPE:

Product Category: Roofing

Sub-Category: Underlayment

Compliance Statement: RhinoRoof U20, ABC Pro Guard 20 and SRS TopShield TS20 Roof Underlayments, as produced by Owens Corning Roofing and Asphalt, LLC, have demonstrated compliance with the following sections of the 6th Edition (2017) Florida Building Code through testing in accordance with applicable sections of the following Standards. Compliance is subject to the Installation Requirements and Limitations / Conditions of Use set forth herein.

2. STANDARDS:

Section	Properties	Standard	Year
1507.1.1, R905.1.1 Exception, 1518.4	Unrolling, Breaking Strength, Pliability	ASTM D226	2009
1507.1.1, R905.1.1 Exception	Tear Strength	ASTM D1970	2015
1507.1.1, R905.1.1 Exception	Tear Strength	ASTM D4533	2015
TAS 110	Accelerated Weathering	ASTM D4798	2011
TAS 110	Pull-through resistance	TAS 117(B)	1995

3. REFERENCES:

Entity	Examination	Reference	Date
ITS (TST1509)	Physical Properties	100539395COQ-006	10/27/2011
ITS (TST1509)	Physical Properties	100539395COQ-002	10/27/2011
ITS (TST1509)	Physical Properties	100539395COQ-006	03/14/2014
PRI (TST5878)	Physical Properties	OCF-330-01-01	09/20/2017
PRI (TST5878)	ASTM D1970; Tear strength	OCF-330-02-02	10/03/2017
PRI (TST5878)	TAS 117(B); Pull-through	OCF-422-02-01	04/03/2018
PRI (TST5878)	ASTM D226, ASTM D4533 (Tear strength)	OCF-464-02-02	12/10/2019
ITS (QUA1673)	Quality Control	Service Confirmation	09/30/2017

4. PRODUCT DESCRIPTION:

	Product	Specification	Plant(s)	Description
4.1	RhinoRoof U20	FBC 1507.1.1 & R905.1.1 (Exception)	Qingdao, China	Multilayered polymer woven coated synthetic roof underlayment
4.2	ABC Pro Guard 20	FBC 1507.1.1 & R905.1.1 (Exception)	Qingdao, China	Multilayered polymer woven coated synthetic roof underlayment
4.3	SRS TopShield TS20	FBC 1507.1.1 & R905.1.1 (Exception)	Qingdao, China	Multilayered polymer woven coated synthetic roof underlayment

5. LIMITATIONS:

- 5.1 This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this Evaluation Report, or previous versions thereof, is/was used for permitting or design guidance unless retained specifically for that purpose.
- 5.2 Fire Classification is not part of this Evaluation Report; refer to current Approved Roofing Materials Directory for fire ratings of this product.
- 5.3 RhinoRoof U20, ABC Pro Guard 20 and SRS TopShield TS20 Roof Underlayments may be used with any prepared roof cover where the product is specifically referenced within FBC approval documents. If not listed, a request may be made to the Authority Having Jurisdiction for approval based on this evaluation combined with supporting data for the prepared roof covering.

5.4 **Allowable Roof Covers:**

TABLE 1: ROOF COVER OPTIONS					
Underlayment	Asphalt Shingles	Tile	Metal	Wood Shakes & Shingles	Slate or Simulated Slate
RhinoRoof U20	Yes	No	Yes	Yes	No
ABC Pro Guard 20	Yes	No	Yes	Yes	No
SRS TopShield TS20	Yes	No	Yes	Yes	No

5.5 **Exposure Limitations:**

RhinoRoof U20, ABC Pro Guard 20 and SRS TopShield TS20 shall not be left exposed for longer than 30-days after installation.

6. **INSTALLATION:**

6.1 RhinoRoof U20, ABC Pro Guard 20 and SRS TopShield TS20 Roof Underlayments shall be installed in accordance with the manufacturer's published installation instructions subject to the Limitations set forth in Section 5 herein and the specifics noted below.

6.2 Re-fasten any loose decking panels, and check for protruding nail heads. Sweep the substrate thoroughly to remove any dust and debris prior to application.

6.3 **RhinoRoof U20, ABC Pro Guard 20 and SRS TopShield TS20:**

6.3.1 **NON-HVHZ Jurisdictions:**

6.3.1.1 Shall be installed in compliance with the requirements for ASTM D226, Type I or II underlayment in FBC Table 1507.1.1 or R905.1.1 for the type of prepared roof covering to be installed, considering the wider sheet-width for double-layer applications.

6.3.1.2 **Fasteners:**

For exposure up to maximum 24 hours, corrosion resistant fasteners may be 1-inch roofing nails with a 3/8-inch diameter head, minimum 1-inch diameter plastic or metal cap nails or FBC HVHZ nails & 1-5/8" diameter tin caps (with the rough edge facing up). The use of staples is prohibited.

For exposure beyond 24 hours up to maximum 30 days, corrosion resistant fasteners shall be minimum 1-inch diameter plastic or metal cap nails or FBC HVHZ nails & 1-5/8" diameter tin caps (with the rough edge facing up). The use of staples is prohibited.

Code Reference: The Exception statement in FBC 1507.1.1 and FBC R905.1.1 states: "...except metal cap nails shall be required where the ultimate design wind speed, V_{ult} , equals or exceeds 150 mph."

Owens Corning Roofing and Asphalt, LLC has furnished data to permit the use of 1-inch diameter plastic cap nails in lieu of metal cap nails for these applications, when the RhinoRoof U20, ABC Pro Guard 20 or SRS TopShield TS20 underlayment is installed beneath mechanically fastened prepared roof covers referenced in FBC Table 1507.1.1 or R905.1.1.

6.3.1.3 **Slopes of 4:12 or greater:**

End (vertical) laps shall be minimum 6-inches and side (horizontal) laps shall be minimum 4-inches. End (vertical) laps shall be offset from course to course not less than 6 feet.

Minimum attachment shall be in accordance with FBC Table 1507.1.1 or R905.1.1. Secure end laps 4-inch o.c. When batten systems are to be installed atop the underlayment, the underlayment need only be preliminarily attached pending attachment of the battens.

6.3.1.4 **Slopes of 2:12 to less than 4:12:**

End (vertical) laps shall be minimum 12-inches and side (horizontal) laps shall be minimum 22-inches. End (vertical) laps shall be offset from course to course not less than 6 feet.

Begin by fastening a 22-inch wide strip along the eaves. Place a full-width sheet over the starter, completely overlapping the starter course. Continue upslope, maintaining minimum 22-inch side (horizontal) laps, resulting in a double-layer application.

Minimum attachment shall be in accordance with FBC Table 1507.1.1 or R905.1.1. Secure end laps 4-inch o.c. When batten systems are to be installed atop the underlayment, the underlayment need only be preliminarily attached pending attachment of the battens.

6.3.2 HVHZ Jurisdictions:

6.3.2.1 Shall be installed in a shingle fashion with minimum 4-inch wide side (horizontal) laps and minimum 6-inch wide end laps.

6.3.2.2 Shall be fastened with FBC HVHZ approved corrosion resistant, 1-5/8" diameter tin-caps and 12 gauge 1.25" long annular ring-shank nails (FBC 1517.5) spaced max. 6-inch o.c. at all laps and 12-inch o.c. at three (3) equally spaced rows in the field of the sheet.

7. BUILDING PERMIT REQUIREMENTS:

As required by the Building Official or Authority Having Jurisdiction in order to properly evaluate the installation of this product.

8. MANUFACTURING PLANTS:

Contact the manufacturer or the named QA entity for plants covered under Rule 61G20-3 QA requirements. Refer to Section 4 herein for product & production locations having met codified physical properties specifications.

9. QUALITY ASSURANCE ENTITY:

Intertek Testing Services NA Inc. – ETL/Warnock Hersey – QUA1673; (604) 520-3321;
peter.gildenstern@intertek.com

- END OF EVALUATION REPORT -