



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

SRS Distribution, Inc.
7440 State Hwy 121
McKinney, TX 75070

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TopShield Pro Underlayment Systems

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA# 24-1001.03 and consists of pages 1 through 5.
The submitted documentation was reviewed by Rafael Macedo.

12/18/25

MIAMI-DADE COUNTY
APPROVED

NOA No.: 25-0820.09
Expiration Date: 11/24/30
Approval Date: 12/18/25
Page 1 of 5

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: SBS

SCOPE:

This approves TopShield Pro Underlayment Systems, as described in this Notice of Acceptance; designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
TopShield PRO SA Cap <i>Manufacturing Location #1</i>	39 $\frac{3}{8}$ " x 33'11" rolls	TAS 103 and ASTM D 6164	Polyester reinforced, self-adhering SBS modified bitumen cap sheet.
Black Diamond™ Base Sheet <i>Manufacturing Location #2, 3</i>	39 $\frac{3}{8}$ " x 68' 7" rolls	ASTM D 1970	Granular surfaced modified, fiberglass reinforced, bituminous sheet material for use as an underlayment in sloped roof assemblies. Designed as an ice & rain shield. Not for use as an Anchor Sheet. Direct adhesion to wood deck not permitted in the HVHZ.

MANUFACTURING LOCATION:

1. Little Rock, AR.
2. Shakopee, MN
3. Pryor, OK

MIAMI-DADE COUNTY
APPROVED

NOA No.: 25-0820.09
Expiration Date: 11/24/30
Approval Date: 12/18/25
Page 2 of 5

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Trinity ERD	CTR-SC11505.12.16	ASTM D1623	12/22/16
	CTR-SC12255.12.16	FM 4474 / UL 1897 / TAS 114	12/27/16
PRI Construction Materials Technologies, LLC	1378T0161	ASTM D8257	5/18/21
	256T0075	ASTM D1970	4/05/22
	256T0114	ASTM D8257	8/30/22
QAI Laboratories	RJ8299P-10	ASTM D8257	02/15/22
	RJ8299P-12	ASTM D8257	03/29/22
NEMO etc., LLC	4q-CTR-19-SSMBB-01.A	ASTM D4601	8/12/19
	4p-DOW-19-SSLAP-01.A-R2	ASTM D1623	02/10/20
	4p-ICP-20-SSLAP-01.A	ASTM D1623	12/15/20
	4j-CTR-20-SSUDL-02.A	Physical Properties	12/16/20
	4j-CTR-21-SSUDL-03.A	TAS 103	08/09/22
	4q-CTR-21-SSMBB-04.E	ASTM D1970	03/08/22
	4j-CTR-22-SSUDL-02.A	ASTM D4977, ASTM D1623	03/09/22
	4q-CTR-21-SSMBB-02.B	ASTM D1970	03/29/22
	4q-CTR-21-SSMBB-04.C	ASTM D4601	4/15/22
	4q-CTR-21-SSMBB-04.G	ASTM D1970	04/15/22
	4a-CTR-LSWUS-001.A	UL 1897	05/29/24
	4a-ACT-LSWUS-002.A	UL 1897	08/08/24
	4q-CTR-23-SSMBB-03.A.R1	ASTM D6164	12/10/24
	4q-CTR-SSMBB-002.A	ASTM D1970	01/06/25
	4q-CTR-SSMBB-006.A	ASTM D4601	04/22/25
Intertek	4j-CTR-SSUDL-001.A	ASTM D1970-17/ TAS 110	09/22/25
	105808719C0Q-001A	ASTM D8257	10/02/24

MIAMI-DADE COUNTY
APPROVED

NOA No.: 25-0820.09
Expiration Date: 11/24/30
Approval Date: 12/18/25
Page 3 of 5

APPROVED ASSEMBLIES:

Deck Type 1: Wood, Non-insulated

Deck Description: $\frac{19}{32}$ " or greater plywood or wood plank

System E(1): Anchor sheet mechanically fastened to deck, membrane adhered.

Anchor Sheet: One or more plies of ASTM D 8257 or ASTM D 2626 with a minimum 4" headlap and a 6" end lap mechanically fastened to deck with approved nails and tin caps 6" o.c. at the side lap edge and in a grid pattern spaced 12" o.c. in the field of the roll.

Membrane: Black Diamond Base Sheet self-adhering membrane adhered to the anchor sheet with a minimum 3" headlap and 6" end lap. Place the first course of membrane parallel to the eave, rolling the membrane to obtain maximum contact. Remove the release membrane as the membrane is applied. Vertical strapping of the membrane is acceptable. If membrane is strapped, then anchor sheet must also be strapped.

Surfacing: Shall be acceptable for use in approved asphaltic shingles, wood shakes, & shingles, quarry slate, and metal roof applications. Must Comply with applicable Roofing Application Standards and Building Codes.

Tile Roofing is not an approved roof covering for use with this assembly.

Deck Type 1: Wood, Non-insulated

Deck Description: $\frac{19}{32}$ " or greater plywood or wood plank

System E(2): Anchor sheet mechanically fastened to deck, membrane adhered.

Anchor Sheet: One ply of ASTM D 226 Type II organic felt mechanically attached with a minimum 4" side lap and a minimum 6" end lap. Anchor sheet shall be applied at a right angle (90°) to the slope of the deck with approved annular ring shank nails and tin caps at a fastener spacing of 6" o.c. at the side lap edge and in a grid pattern spaced 12" o.c. in the field of the roll of the base sheet.

Ply Sheet: One or more plies of an ASTM D 226 ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

(Optional)

Membrane: One ply TopShield PRO SA Cap, self-adhering membranes adhered to the preceding sheet with a minimum 4" side lap and 6" end lap. Place the first course of membrane parallel to the eave, rolling the membrane to obtain maximum contact. Remove the release membrane as the membrane is applied. Vertical strapping of the membrane is acceptable. If membrane is strapped, then anchor sheet and ply sheet must also be strapped.

Surfacing: Approved for Metal Roofing, Wood Shake & Shingles, and Asphaltic Shingle assemblies.

Tile Roofing is not an approved roof covering for use with this assembly.

LABELING:

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

LIMITATIONS:

1. Fire classification is not part of this acceptance.
2. TopShield Pro roofing systems utilizing Black Diamond Base Sheet as a cap membrane shall be acceptable for use in asphaltic shingles, wood shakes, & shingles, quarry slate, and metal roof applications.
3. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code. TopShield Pro underlayment roofing systems shall be installed in strict compliance with applicable Building Code.
4. TopShield Pro underlayment roofing systems membranes shall be applied to a smooth, clean and dry surface with deck free of irregularities.
5. TopShield Pro underlayment roofing systems membranes shall not be applied over an existing roof membrane as a recover system but may be applied over an approved roofing Base/Anchor sheet underlayment.
6. TopShield PRO SA Cap and shall not be left exposed as a temporary roof for longer than 180 days of application. Black Diamond Base Sheet shall not be left exposed as a temporary roof for longer than 30 days after application.
7. TopShield Pro underlayment products may be used with any approved roof covering Notice of Acceptance listing TopShield Pro underlayment products as a component part of an assembly in the Notice of Acceptance. If TopShield Pro underlayment products are not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or Miami-Dade County Product Control for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
8. All nails in the deck shall be carefully checked for protruding heads. Re-fasten any loose decking panels. Sweep the deck thoroughly to remove any dust and debris prior to application.
9. When applying the membrane in the valley, start at the low point and work to the high point, rolling the membrane from the center outward in both directions.
10. Roll or broom the entire membrane surface so as to have 100% contact with the surface, giving special attention to overlap areas.
11. Flash vent pipes, stacks, chimneys and penetrations in compliance with Roof Assembly current Product Control Notice of Acceptance and applicable Building Code.

END OF THIS ACCEPTANCE



NOA No.: 25-0820.09
Expiration Date: 11/24/30
Approval Date: 12/18/25
Page 5 of 5